


Energy Conservation in Existing Buildings Process and Results

Julie Walleisa, Dekker/Perich/Sabatini
David Lyle, Beaudin Ganze Consulting Engineers, Inc.



Agenda



- Assessing Buildings
 - Tools/Process
 - Case Studies
 - Incentives
- Improving Buildings
 - Energy Conservation Measures
 - Case Studies





Introduction



Julie Walleisa, AIA, LEED AP

- Licensed architect
- Focused on building performance – functionality, energy efficiency, overall sustainability
- Associate with Dekker/Perich/Sabatini

Dekker/Perich/Sabatini

- 200+ architects, structural engineers, landscape architects, planners, and interior designers
- Offices in Albuquerque, Las Vegas, Amarillo
- Part of ownership team on our own LEED Gold office building



Building Assessment




- Compare performance to national or local averages, or the rest of your portfolio
- Identify opportunities for improvement and ongoing cost savings
- Discover whether the building may qualify for any incentives or recognition
- Decide what team members and level of analysis is needed upfront





Benchmarking

- What's needed?
 - 1 year of typical utility bill data
 - Average to compare against
- Compare to building history or your portfolio
- CBECS Database
 - Commercial Building Energy Consumption Survey
 - Calculate building EUI and compare to table



Benchmarking

CBECS (excerpt)

TABLE 1 2003 CBECS¹ National Average Source Energy Use and Performance Comparisons by Building Type


Building Use Description ²	Average Source EUI ³ (Kbtu/Sqft)	Average Percent Electric	Average Site EUI (Kbtu/Sqft)
Education	170	63%	76
K-12 School	See Target Finder / Portfolio Manager		
College/University (Campus-level)	280	63%	120
Food Sales	681	86%	225
Grocery Store/Food Market	See Target Finder / Portfolio Manager		
Convenience store (with or without Gas Station)	753	90%	241
Food Service	786	59%	351
Restaurant/Cafeteria	612	53%	302
Fast Food	1306	64%	534
Health Care: Inpatient (Specialty Hospitals, Excluding Children's)	468	47%	227
Hospital (Acute Care, Children's)	See Target Finder / Portfolio Manager		
Health Care: Long Term Care (Nursing Home, Assisted Living)	255	54%	124
Health Care: Outpatient	183	72%	73
Clinic/Other Outpatient Health	219	76%	84
Medical Office	See Target Finder / Portfolio Manager		



Benchmarking



- ENERGY STAR's Portfolio Manager tool
 - Requires additional usage data to normalize
 - Enter and track information online
 - Can only benchmark certain building types:
 - Offices
 - K-12 Schools
 - Hospitals
 - Hotels
 - Supermarkets
 - Residence Halls/Dormitories
 - Warehouses
 - Medical Offices
 - Retail Space



Benchmarking



Portfolio Manager: Multiple Buildings

GROUP: All Facilities | Create Group | View All | VIEW: Summary: Facilities | Create View | Edit View | View All

Download in Excel | Search Facility Name: [] Search

Results 1 - 3 of 3 | All # A B C D E F G H I J K L M N O P Q R S T U V W X Y Z

Facility Name	Current Rating (1-100)	Change from Baseline: Adjusted Energy Use (%)	Total Floor Space (Sq. Ft.)	Energy Use Alerts	Current Energy Period Ending Date	Eligibility for the ENERGY STAR	Last Modified
Jefferson Green	43	0.0	116,540	Data > 120 days old	12/31/2007	Not Eligible: Rating must be 75 or above (ENERGY STAR Eligibility Rules)	01/31/2008
Sample Facility	99	1.2	85,000		03/31/2009	Apply for the ENERGY STAR	09/11/2009
Sample Facility	56	NA	15,000	Data > 120 days old	10/31/2007	Not Eligible: Rating must be 75 or above (ENERGY STAR Eligibility Rules)	01/31/2008

Download in Excel | Search Facility Name: [] Search

Results 1 - 3 of 3 | All # A B C D E F G H I J K L M N O P Q R S T U V W X Y Z



Benchmarking

Portfolio Manager: Additional Inputs

*Space Name:

Current Space Attribute Values <small>What is this?</small>	
Space Attribute	Space Attribute Value (Temporary values should only be used if an Actual value is not currently known) <small>What is this?</small>
Gross Floor Area (required for benchmarking)	85000
Weekly operating hours (required for benchmarking)	55
Workers on Main Shift (required for benchmarking)	284
Number of PCs (required for benchmarking)	284
What percent of this space is air-conditioned? (required for benchmarking)	50% or more
What percent of this space is heated? (required for benchmarking)	50% or more

Benchmarking

Portfolio Manager: Meter data

Energy Meters <small>Add Meter Update Multiple Meters View All Meter Data in Excel</small>					
Meter Name	Energy Type	Space(s)	Last Meter Entry (End Date)	Alerts	
electric	Electricity (kWh)	Entire Facility	05/02/2009		Delete Meter
gas	Natural Gas (therms)	Entire Facility	05/04/2009		Delete Meter

Water Meters <small>Add Meter View All Meter Data in Excel</small>					
Meter Name	Units	Use	Last Meter Entry (End Date)	Alerts	
No Meter Defined					

Benchmarking

Portfolio Manager: EUI, Rating



Facility Summary: Jefferson Green

Building ID: 1431683
Level of Access: Facility/Profile Editor
Access Provided by: Caryn Grosse
Electric Distribution Utility: PNM - Public Service Co of NM
Regional Power Grid: [BRC: Southeast](#)
Select my Power Generation Plant to calculate my electric emissions rate
Electric Emissions Rate (kgCO₂e/MBtu): 175.1 ([what is this?](#))

General Information	
Address: 7601 Jefferson NE, Albuquerque, NM 87109	
Year Built: 2006	
Property Type: Single Facility	
Baseline Rating: 99	Current Rating: 99
Eligible to Apply for the ENERGY STAR	

Generate a Statement of Energy Performance for uses other than applying for the ENERGY STAR.

12 Months Ending	Current Rating (1-100)	Current Site Energy Intensity (kBtu/Sq. Ft.)	Current Source Energy Intensity (kBtu/Sq. Ft.)	Change from Baseline: Energy Use Intensity (kBtu/Sq. Ft.)	Change from Baseline: Adjusted Energy Use Intensity (kBtu/Sq. Ft.)	Energy Use Alerts
February 2009	99	34.5	82.7	-1.3	0.3	
Select Date						
Change						




Benchmarking



- Preliminary analysis:
 - Online Q&A tools
 - Energy modeling
- What can benchmarking and preliminary analysis tell you?
 - Already performing well
 - Performing poorly in areas that might be difficult to address
 - Clear areas of potential improvement and operating savings



Case Study #1:



Case Study #1:



- 14,500sf building
- Wood frame, stucco, built up roof
- Packaged RTUs
- Leased: courtrooms, offices, support spaces
- **Step 1: Portfolio Manager benchmarking of utility bills**
- **EUI 26kBtu/sf = ES rating of 92**







Case Study #1:


- Not likely to be significant/cost effective gains, unless systems at end of life
- Don't need model to study physical changes
- Submit for ENERGY STAR recognition
- Focus on operational tweaking
 - Schedules, office equipment, maintenance
- Consider retrocommissioning
 - \$0.30-0.70/sf = \$4,000 to \$10,000



Case Study #2:










Case Study #2:

- 15,000sf building
- Leased: restaurant, retail stores
- Masonry units, stucco, tan roof
- Mix of single and double pane windows
- Packaged RTUs, mix of T12, T8, MR16 lights
- **Step 1: Utility benchmarking**
 - Restaurant use = CBECS required
- **Step 2: Energy modeling**
 - Synchronized to utility bills
 - Breakdown of energy uses








Case Study #2:


Building Summary		
Area	14,825	ft ²
Site Energy Use	169	kBtu/ft ² /yr
Source Energy Use	311	kBtu/ft ² /yr
Energy Cost	3.00	\$/ft ²

Energy Usage (kBtu/yr)	
Lighting	375,318
Space Heating	61,947
Space Cooling	208,517
Fans	204,403
Process Loads	1,668,742
Total	2,518,928



Energy Usage



- 169 kBtu/sf/yr EUI
- 66% process loads
- Only 11% heating and cooling



Case Study #2:




- High gas use year-round due to restaurant
- Restaurant use exceeds allowable LEED EUI
- Process uses overshadow potential base building improvements
- Can't qualify for LEED-EB, considering LEED-CS

Case Study #3:

Scope: LEED-EB feasibility

Low performer with clear opportunities & challenges




Case Study #3:

BEAUDIN GANZE consulting engineers, inc.

- 13,000sf office building built in 2000
- 6" metal stud, cavity insulation, stucco
- Tinted double paned windows
- Multiple packaged RTUs on central thermostats with timed setbacks
- Mostly T12 lighting
- **Step 1: utility benchmarking & building walkthrough**
- **125 kBtu/sf/yr = EPA rating of 31**
- **Energy 35% higher than LEED-EB threshold**


Dekker/Perich/Sabatini



Case Study #3:

BEAUDIN GANZE consulting engineers, inc.


- Major changes needed to meet LEED-EB, reduce utility costs
- Preliminary analysis done with Business Analyzer from www.energyguide.com

BusinessAnalyzer  save energy and improve productivity and profits


Use Business Analyzer to conduct a self-guided, energy-efficiency analysis of your small or mid-sized business.

Energy efficiency is not just about saving energy:


- Improve the productivity & comfort of employees and customers.
- Check out competitive offers from suppliers of Electricity, Gas, or Oil.
- Improve the maintenance, safety & security of your operation.
- Compare your facility's energy use to its peers.
- AND lower your energy bill - all at the same time!

 Analyze Your Business

Dekker/Perich/Sabatini



Case Study #3:



Please tell us about your energy bill:

	Don't Have / Don't Pay	Electric	Gas	Propane	Oil
Heating (primary): *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Heating (secondary): *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Cooling (primary): *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
Cooling (secondary): *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
Water Heating: *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
Refrigeration: *	<input type="radio"/>	<input type="radio"/>			
Cooking: *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Laundry: *	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	
Interior Lighting: *	<input type="radio"/>	<input type="radio"/>			
Exterior Lighting: *	<input type="radio"/>	<input type="radio"/>			

What percentage of total area is ...

... Heated?

... Cooled?


Opening Time / Start-up

Weekdays (M-F) *

Saturday *


Sunday, Holidays *

Closing Time / Shut-down





Case Study #3:



What type(s) of **INTERIOR** lighting do you use?

	Most	Some	Few	None
Incandescent	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
standard fluorescent	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
compact fluorescent	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
metal halide	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
mercury vapor	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>
other HID	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>

If applicable, what type of fluorescent tubes are installed?

T-12 standard fluorescent

T-12 energy-saver fluorescent

T-8 energy-efficient fluorescent

Other

Unsure

None

What type of fluorescent ballasts are installed?

Magnetic ballasts (typical, for T-12's)

Electronic ballasts (standard, for T-8's)



Don't know/don't have fluorescents

Do you have occupancy sensors or other automatic lighting controls?

Yes

No







Ideal Case

- Performance is in average to low range
- Systems nearing time for replacement
 - Able to upgrade lighting and HVAC
 - Able to consider insulation, roof, glazing improvements
- Load mostly base building, not processes
- Possibility of integrating renewable energy



Incentives

- Beyond operating savings:
 - State tax credits
 - Local utility programs
 - Solar incentives
 - Higher occupancy rates
 - Higher rental rates
 - Higher sales price



Incentives

- **NM Sustainable Building Tax Credit**
 - LEED-EB Silver or Higher
 - Less than half the average energy use
 - from \$1.40/SF for LEED CI Silver to \$6.25/SF for LEED NC Platinum

	First 10,000 ft ²	Next 40,000 ft ²	Next 450,000 ft ²
LEED-NC New construction			
Silver	\$3.50/ft ²	\$1.75/ft ²	\$0.70/ft ²
Gold	\$4.75/ft ²	\$2.00/ft ²	\$1.00/ft ²
Platinum	\$6.25/ft ²	\$3.25/ft ²	\$2.00/ft ²
LEED-EB/CS Existing building/Core and shell			
Silver	\$2.50/ft ²	\$1.25/ft ²	\$0.50/ft ²
Gold	\$3.35/ft ²	\$1.40/ft ²	\$0.70/ft ²
Platinum	\$4.40/ft ²	\$2.30/ft ²	\$1.40/ft ²
LEED-CI Commercial interiors			
Silver	\$1.40/ft ²	\$0.70/ft ²	\$0.30/ft ²
Gold	\$1.90/ft ²	\$0.80/ft ²	\$0.40/ft ²
Platinum	\$2.50/ft ²	\$1.30/ft ²	\$0.80/ft ²



Incentives

- **PNM Commercial Rebate Programs**
 - Lighting retrofits, up to \$75/fixture
 - Advanced evaporative cooling, up to \$500/unit
 - Peak Saver program, quarterly incentives
 - http://www.pnm.com/rebates/business_rebates.htm



Incentives



- **Solar Incentives**
 - Federal tax credit: 30% system cost, no cap
 - NM tax credit: additional 10% of system cost
 - <http://www.emnrd.state.nm.us/ecmd/index.htm>
 - PNM Large PV program: 15 cents/kWh
 - http://www.pnm.com/customers/pv_large/home.htm?source=smallpv







Lease/Sales/Occupancy

- CoStar Study: Does Green Pay Off?
 - Analyzed over 1,300 LEED and Energy Star buildings
 - Over 350 million square feet
 - Assessed buildings against non-green properties with similar size, location, class, tenancy and age characteristics
 - <http://www.costar.com/josre>
 - Not yet evident in our market









Next Steps

- Benchmarking:
 - In-house or by consultant
- Analysis:
 - Self-analysis with online Q&A tools
 - Energy modeling analysis
 - Retrocommissioning
 - Incentive/tax analysis
- Reporting to management/boards:
 - Detailed analysis results
 - Cost/savings estimates

Next Steps


ENERGY MODEL SUMMARY

*The Energy Model Summary is a means of energy use comparison and may vary slightly from actual building performance.


Building Summary		
Area	14,825	ft ²
Site Energy Use	169	kBtu/ft ² /yr
Source Energy Use	311	kBtu/ft ² /yr
Energy Cost	3.00	\$/ft ²

Environmental Impact		
CO2	2,895,786	lbm/yr
SO2	5,480	gm/yr
NOX	6,938	gm/yr


Energy Usage (kBtu/yr)	
Lighting	375,318
Space Heating	81,947
Space Cooling	208,517
Fans	204,403
Process Loads	1,668,742
Total	2,518,928



Annual Energy Cost		
Energy Source	Total Energy	Total Cost
	kBtu/yr	\$/yr
Electricity	1,013,128	28,567
Gas	1,505,800	15,664
Total	2,518,928	44,531



Monthly Energy Summary		
Month	Electricity Use	Gas Use
	kWh	therms
January	21,374	1,312
February	20,054	1,177
March	22,233	1,249
April	24,052	1,187
May	26,638	1,226
June	27,710	1,187
July	26,470	1,226
August	28,525	1,226
September	26,865	1,187
October	25,715	1,226
November	21,876	1,225
December	22,531	1,433



Next Steps

SUMMARY OF RECOMMENDATIONS

Credit	Recommended Changes	Changes Are:		Estimated Cost
		Physical	Operational	
SSc2	Ice and snow removal, exterior cleaning paints and sealants	X	X	
SSc3	Pest control, erosion/sedimentation control(construction)		X	
SSc4	Survey occupants about commuting behaviors		X	
SSc7.1	Replace part of sidewalk Clean every 2 years	X	X	
SSc7.2	Coat roof Clean every 2 years	X	X	
SSc8	Install controls	X		
WEp1	Add aerators to lav faucets Assessment Policy for future renovations	X	X	
WEc2	Replace toilets with 1.1 gpg-3 points Also replace urinals with 0.5 gpf-5 points	X	X	
EAp1	Sequence of operations and audit done as part of report		X	
EAc2.1	Audit done as part of report		X	
EAc2.2	Initiate commissioning		X	\$5,000 one-time
EAc2.3	Ongoing commissioning-every 2 years		X	\$5,000 every 2 years
EAc3.3	Add submeters for main service, retail spaces, basement	X		\$6,000/one-time
EAc4	2 year contract for off-site and/or Add PV system for on-site	X	X	\$1,032-\$6,331/year \$96,000/one-time

Next Steps

EAp2: Minimum Energy Efficiency Performance (required)

Prerequisite Summary:
This prerequisite uses the energy performance of similar buildings to establish a baseline for energy efficiency. The requirements provide three options: for buildings which achieve an ENERGY STAR rating of at least 99, for buildings which demonstrate energy efficiency at least 19% better when benchmarked against buildings of the same type, and for buildings for which no comparable data is available.

Status and Recommendations:
The ENERGY STAR rating is not applicable to all building types, such as the restaurant at ... so Option B was selected as the most appropriate way to establish energy efficiency baseline.

Typically, CBECS (Commercial Buildings Energy Consumption Survey) is used to benchmark buildings for which an ENERGY STAR rating is not available, however, USGBC has adjusted the national averages for certain categories, including Food Service-Restaurant/Cafeteria, in their calculator to keep the levels more consistent with the expected levels for other building activities. The result is that ... is unable to meet the prerequisite due to the high energy use of the restaurant. ... would not be able to meet this requirement even with major improvements to the HVAC system, since the issue relates to the energy consumption associated with the restaurant, rather than the base building systems.



Gas meters used for evaluation of EAp2 and EAc1

ENERGY & ATMOSPHERE

EAp3: Refrigerant Management: Ozone Protection (required)

Prerequisite Summary:
This prerequisite prohibits the use of chlorofluorocarbon (CFC) based refrigerants for heating, ventilation, air conditioning and refrigeration (HVAC/R) systems unless it can be shown that replacing the system is not economically feasible or a phase-out plan for the CFCs is in place.

Status and Recommendations:
... could achieve this prerequisite without changes. R-22 refrigerant is used in all HVAC and refrigeration equipment and is permissible for this prerequisite.




Kitchen refrigerator compressors. The R-22 refrigerant complies with EAp3, but not with EAc5.


Next Steps



This chart shows the Site Energy Use Intensity (kBtu/s/yr) which must be achieved in order to obtain an ENERGY STAR rating of 80 and the corresponding Total Annual Site Energy (kBtu).

Building Number	Building Name/Type	Year Built	Square Footage (6,000 sf min)	number of students/occupants	number of PC's	operating hours/week	operating months/year	cooking facilities	AC's (mech. cooled)	Heated %	Ventilated (mech. ventilated)	results	
												Site Energy Use Intensity (kBtu/s/yr)	Total Annual Site Energy (kBtu)
000	Science Classrooms	1990	8,777	142	4	48	10	No	100	100	Yes		
000A	Math Classrooms	1993	2,328	38	5	48	10	No	100	100	Yes		
-	Observatory and Physics Classroom	2005	1,170	20	2	40	10	No	90	90	Yes	40.2	533,181.1
Total, Building 000			13,275	208	11	48	10	No	90	90	Yes		
100	Administration	1967/78/78/92	11,535	20	17	48	n/a	n/a	n/a	n/a	n/a		
100	Classrooms	1967/78/78/92	4,092	108	44	48	10	No	100	100	Yes		
Total, Building 100			15,627	126	61	48	10	0	100	100	0	48.6	760,035.0
200	Classrooms	2002	26,000	390	33	48	9	No	100	100	Yes	44.4	1,113,932.9
300	Classrooms	1960	5,500	73	5	40	10	No	100	100	Yes	39.0	219,691.3
500	Classrooms, Music, Photography	1983	6,930	165	12	48	10	No	100	100	Yes	45.4	314,384.5
600A	Student Center	2002	15,000	333	9	40	10	Yes	100	100	Yes	47.1	705,975.7
600	Library	1990	7,133	100	63	48	10	No	100	100	Yes	52.8	376,733.4
700	Art/Shop	1978/1995	2,280	30	1	48	10	No	100	100	Yes	Cannot be analyzed, building is too small	
-	Performing Arts Center	1990	8,130	312	5	55	10	No	100	100	Yes	45.0	365,633.0
-	West Gymnasium	1991	22,200	333	3	60	10	No	100	100	Yes	37.5	833,329.8





Introduction

BEAUDIN GANZE consulting engineers, inc.


David A. Lyle, P.E., LEED, CxA

- Professional Engineer
- Commissioning Agent
- 15 years Design, Installation and Operation experience with HVAC Systems
- Principal for Beaudin Ganze Consulting Engineers, Inc.

Beaudin Ganze Consulting Engineers

- 18 Year old Consulting Engineering Firm
- 55 Employees across 6 offices around the country
- Provides existing building services including:
 - Energy Audits
 - Retro Commissioning
 - LEED EB Feasibility Studies
 - Engineering Design and Analysis

Dekker/Perich/Sabatini
architect interior services landscape planning engineers



Energy Conservation Measures (ECMs)


BEAUDIN GANZE consulting engineers, inc.

What is an ECM:

Unique, systematic modification to system(s) or process(es) to improve performance, reduce operating costs, increase asset value.

OPR/OFR and BoD/DI compliant
Often similar for building/sector types

Dekker/Perich/Sabatini
architect interior services landscape planning engineers




Energy Conservation Measures (ECM's)

BEAUDIN GANZE
consulting engineers, inc.

- **Low Hanging Fruit:**
 - **Usually identified in basic energy assessment/audit**
 - benchmarking process
 - simple walkthrough
 - Commissioning often addresses
 - 0-36 month ROI
- **Other opportunities:**
 - **Found in more detailed building system energy assessment /audit**
 - May require energy modeling
 - More detailed economic analysis required
 - 36+ month ROI

Dekker/Perich/Sabatini
architectural services landscape planning engineering




Energy Conservation Measures (ECMs)

BEAUDIN GANZE
consulting engineers, inc.

Primary ECM Categories:

- Operation and Maintenance (O&M)
- HVAC
- Plumbing
- Power and Lighting
- Envelope

Dekker/Perich/Sabatini
architectural services landscape planning engineering



O&M ECM's Commissioning:



- Retro/Re Commissioning (Cx) is a systematic, quality process for improving the current conditions and operations of an *existing* building.
- Building Systems most commonly addressed include:
 - HVAC
 - Lighting Controls
 - Domestic Hot Water
 - Building Envelope
- Retro-Cx evaluates the conditions of the buildings energy related systems, and optimizes the operation, performance, and maintenance in accordance with the original design intent and the owner's operational needs.



O&M ECM's Commissioning:



- Retro/Re-Cx is analogous to a tune up for your building, establishing or restoring the building's operation to the design intent.





O&M ECM's Commissioning:



- **Benefits:**

- Determines root cause of the problem to optimize building systems – not quick fix.
- Validates BoD and established baseline.
- Corrections are typically low cost measures to implement. Can be funded through O&M budget, not requiring capital funds.
- Improvement in temperature control, indoor air quality, and energy efficiency
- Paybacks are typically 6 months to 2 years
- Allows for training of O&M staff to sustain ongoing building performance improvement



O&M ECM's Commissioning:



- **Costs/Savings:**

- Median commissioning costs of \$0.27/ft²
- Median building energy savings of 15 percent
- Median payback of 0.7 years.
- The most cost-effective results occurred among energy-intensive facilities such as hospitals and laboratories. Less cost-effective results are most frequent in smaller buildings. Energy savings tend to rise with increasing comprehensiveness of commissioning.
- We find that commissioning is one of the most cost-effective means of improving energy efficiency in commercial buildings

2004 Assessment - Lawrence
Berkeley National Laboratory





O&M ECM's Preventative Maintenance:

BEAUDIN
GANZE
consulting engineers, inc.


How do you operate?

“The best offense is a good defense”

Or

“The best defense is a good offense”

Dekker/Perich/Sabatini
architectural services landscape planning engineering



O&M ECM's Preventative Maintenance

BEAUDIN
GANZE
consulting engineers, inc.

- **Benefits:**
 - Improved system reliability.
 - Decreased cost of replacement.
 - Decreased system downtime.
 - Better “spares” inventory management.
 - Better staff management (limited overtime, increased efficiency).

Dekker/Perich/Sabatini
architectural services landscape planning engineering




**O&M ECM's
Preventative Maintenance**

BEAUDIN
GANZE
consulting engineers, inc.

- **Savings:**
 - Vary – case by case, but long-term effects and cost comparisons usually favor preventive maintenance over performing maintenance actions only when the system fails.

Preventing fires is much easier than putting them out!

Dekker/Perich/Sabatini
architect interior landscape planning engineers




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Controls:**
(adjustment/enhancement/replacement/integration)
- **Examples:**
 - Occupancy Sensors\Scheduling
 - Integration with other systems – lighting, heating, air conditioning, power, security, etc.
 - Ventilation Control
 - Setback/Reset - air, water
 - Setpoint adjustment (heating water, pressure, chilled water, supply air, etc.)

Dekker/Perich/Sabatini
architect interior landscape planning engineers




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Controls:**
 - **Benefits:**
 - Identified early in process.
 - Low or No Cost if system already in place.
 - Can be done relatively quickly.
 - Enhanced system performance and occupant comfort.

Dekker/Perich/Sabatini
architect interior landscape planning engineers




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Controls:**
 - **Costs/Savings:**
 - Typically this is the area where Cx pays for itself with 10%-30% building energy savings (even with newly constructed bldgs. 0 to 36 month ROI)
 - Adding whole Building Automation Systems and/or Energy Management Systems to existing building is cost prohibitive unless incentives are available.
 - Varied other cost if adding control points, controllers, and programming.

Dekker/Perich/Sabatini
architect interior landscape planning engineers




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Equipment Upgrades/Replacement:**
 - **Examples:**
 - Variable speed motors (fans and pumps)
 - High efficiency equipment
 - Modulating vs. Two Position
 - Energy recovery
 - Economizer
 - Evaporative Cooling (direct/indirect)
 - Insulation (piping and equipment)

Dekker/Perich/Sabatini
architectural services mechanical plumbing engineering




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Equipment Upgrades/Replacement:**
 - **Benefits:**
 - Enhanced system performance and occupant comfort.
 - Reduced operating costs.
 - Increased asset value.

Dekker/Perich/Sabatini
architectural services mechanical plumbing engineering




HVAC ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Equipment Upgrades/Replacement:**
 - **Costs/Savings:**
 - Varies significantly on the upgrade, facility type, accessibility, etc.
 - Smaller changes like variable speed motors and/or modulating devices result in more acceptable 3 to 7 year payback.
 - 10% to 50% savings range is typical; however often not enough to provide a reasonable ROI given the costs of implementation.
 - Most viable when equipment or systems are scheduled for replacement or significant renovation.

Dekker/Perich/Sabatini
architect interior design landscape planning engineers



Plumbing ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Examples:**
 - Low/No flow fixtures
 - Grey water or other process water recovery and reuse.
 - Storm water recovery and use.
 - High efficiency domestic water heater.
 - On demand domestic water heater.
 - Heat recovery.
 - Renewable – Solar water heating

Dekker/Perich/Sabatini
architect interior design landscape planning engineers




Plumbing ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Benefits:**
 - Reduced operating costs.

Dekker/Perich/Sabatini
architect interior landscape planning engineers




Plumbing ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Costs/Savings:**
 - 20%-30% potable water usage typical savings. 5-10 year ROI depending on baseline water usage and quantity of fixtures.
 - Energy savings 10% to 30% common on higher efficient or on demand domestic hot water systems. 5-7 year ROI depending on baseline water usage and system size.
 - Energy savings of 1% to 2% with 3-5 year ROI on standby loss prevention of piping and equipment if easily accessible for application.

Dekker/Perich/Sabatini
architect interior landscape planning engineers



Power and Lighting ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Examples:**
 - High efficiency lighting and ballasts
 - Load shedding/Demand Shaving
 - Dimming
 - Scheduling/Occupancy (lighting and power)
 - Renewable – photovoltaic, wind turbines, day lighting, other.
 - Power factor correction

Dekker/Perich/Sabatini
architectural services landscape planning engineers



Power and Lighting ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Benefits:**
 - Reduced operating costs.
 - Enhanced performance.
 - Enhanced occupant comfort with day lighting.

Dekker/Perich/Sabatini
architectural services landscape planning engineers



Power and Lighting ECM's



- **Costs/Savings:**
 - Cost vary based on system configuration and accessibility.
 - Controls – dimming, occupancy, scheduling, relatively low cost with ROI of 0-36 months.
 - 2% to 5% energy savings from controls, power/lighting scheduling.
 - Savings for lighting/ballast change out can be minimal or significant depending on the baseline system. Typically see 3-7 year paybacks.
 - Savings from renewable solutions varies with the quantity that can be installed. ROI is typically not feasible without incentives/credits.



Building Envelope ECM's



- **Examples:**
 - Fenestration Improvement/Shading/Replacement
 - Envelope Insulation
 - Infiltration/Ex-filtration






Building Envelope ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Benefits:**
 - Reduced operating costs.
 - Enhanced occupant comfort with day lighting.

Dekker/Perich/Sabatini
architect interior landscape planning engineers



Building Envelope ECM's

BEAUDIN
GANZE
consulting engineers, inc.

- **Costs/Savings:**
 - Cost vary based on system configuration and accessibility.
 - Immediate energy savings on infiltration improvements with ROI of 0-36 months.
 - 2% to 5% energy fenestrations improvements with coatings and/or shading. ROI of 3-7 years.
 - Savings from fenestration replacement or envelope insulation improvements vary significantly depending on the baseline installation. Amount of savings drives ROI.

Dekker/Perich/Sabatini
architect interior landscape planning engineers



Case #1 – Energy Audit



Engineering Consulting Saves Manitou Springs School District Money and Energy

Scope: update and improve the performance of nine buildings located on three campuses – the oldest built in the early 1900s.

Issues: District had completed several additions and expansions operating at higher than expected energy use costs and had systems that were not providing the level of heating and ventilation required for the health and comfort of the students and staff.

Process: Engineer/Cx evaluated the buildings for energy consumption, controllability, functionality, and whether they were performing as needed to match the current academic curriculum of the District.



Case #1 – Energy Audit



Team used Integrated Energy Modeling which allowed the team to select a package of energy conservation measures:.

- A District-wide BACNet DDC system
- Occupancy sensors to control lighting and HVAC equipment
- Variable Frequency Drives (VFDs) on fan-powered equipment and pumps
- Reducing the existing heating plant capacity by 22 to 33%
- Reduced DHW plant size by 64.4%
- Condensing boilers to replace aged cast-iron boilers
- High efficiency domestic water system.
- Economizer actuators and dampers with DDC control by CO2 sensors
- Commissioning of the mechanical and electrical systems.





Case #1 – Energy Audit

Project budget: \$2,012,966

Savings: Gas usage has been reduced 64% and electric usage 46%. Additionally, atmospheric carbon dioxide has been brought down by 2.2 million pounds or 53%. In first nine months of 2008, MSSD has saved \$135,000. Project to an approximately 10 year payback

Benefits: improved comfort, lower operating costs, easier maintenance conditions, improved safety and security of the buildings, and better overall quality to the classroom environment. These projects enhanced the comfort, health, safety, and learning environment within the School District's buildings, and demonstrate how effectively operational energy savings can be realized in school districts with aging, outdated, poorly installed, or improperly sized equipment.



Case #2 – Retro Cx

Facility: Adobe headquarters, three towers totaling 989,000 square feet of office space

Project Timeline: 2001-2006

Costs: \$1.4 million (\$1.1 million after incentives)


Savings: \$1.2 million per year

Simple Payback: 9 months

Costs/Savings:

- Energy cost savings: \$1.2 million per year 35% (electricity), 41% (natural gas)
- All three buildings earned EPA ENERGY STAR® labels with scores of 98, 100, and 100 (does not include data centers)
- LEED®-EB Platinum Certification on all three buildings





Case #2 – Retro Cx

Details/Process:

Two towers, built in 1996 and 1998. Third tower built in 2003

The facilities team was well-trained and including a fifth-generation building engineer with an industrial science degree.

Buildings had never been fully commissioned

After five years of occupancy the towers were retro-commissioned



Case #2 – Retro Cx

Details/Process:

Energy audit performed and implement a number of O&M and retrofit measures to fix problems identified in the audit.

More than 60 measures were implemented over a five-year period. After the first dozen measures were implemented, the results paved the way for approval of further projects.

“We took one project at a time, looking at the costs, seeing what the rebate would be, estimating savings, implementing, testing. After a while it became routine.”

Tower three was built in 2003 and was not fully commissioned and had a **score of 50 (energy star)** as a new building due to the constant operation of a chiller to cool the data centers and software labs. After **retro-commissioning, the building's score increased to 83.**



Case #2 – Retro Cx



Adobe compares building optimization to tuning up a car.

“Without a tune-up, the performance gets worse and worse until eventually the car is inoperable. Before our retro-commissioning program, the Adobe West Tower was approaching that,”

with hundreds of tenant comfort complaints each month. Now, the three buildings combined generate 20 to 40 calls per month, depending on the season.



Questions ???



Thank You!
Dekker/Perich/Sabatini
Beaudin Ganze

